

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3230-0751:107 Page 1 of 1

CATEGORY: Leakage Dampers

LISTEE: Safe-Air, 1855 South 54th, Cicero IL 60804
Contact: *Lee Stack (708) 652-9100 Fax (708) 652-9158

DESIGN: Model 682 leakage rated damper. Refer to listee's data sheet for detailed product description and operational considerations. The sizes of dampers are as follow:

<u>Width</u>	<u>Height</u>	<u>Mounting Position</u>
Min.	Max.	
8"	48"	Vertical and Horizontal

RATING: Class II-350

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL Listed as 1/2-hour leakage rated dampers. Suitable for vertical and horizontal installations.

*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 16, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager